

DATE: May 04, 2009

TO: Prospective Proposers

RE: Addendum #3 to the Proposal Documents for
Facility Improvements
Martins Mill ISD
Martins Mill, Texas



2009-05-04

NOTICE TO PROPOSERS:

This Addendum forms a part of the Contract Documents and modifies the original proposal documents dated April 08, 2009 noted below. Acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject Proposer to disqualification.

This Addendum consists of **01** page.

PROJECT MANUAL ITEMS

ITEM # PM 1

SECTION 08520 – ALUMINUM WINDOWS: PART 2 - PRODUCTS:

Clarification: Bid using the "Columbia, Series 3550 single hung window" as per the specs & not the top hung windows shown on sheet A7.0/Window Frame Elevations

ITEM # PM 2

SECTION 10000 – MISCELLANEOUS SPECIALTIES:

ADD: Skylights: Provide as follows, manufactured by Naturalite. Provide Square, #PNTL - 5151.

ARCHITECTURAL

ITEM A1

1. Clarification regarding Alternate # 3

This alternate refers to installing CT wainscot in existing & new corridors and is called out on: A2.2/01, Keyed Note 04; A2.3/01, Keyed Note 04; A5.1/10 & A6.0/13.

In the **existing corridor** this alternate *includes* removing the first 4ft (AFF) of gyp board & replacing it with cement board to facilitate tile wainscot installation. In the **new corridors**, this *includes* installing cement board at the locations where the CT wainscot occurs.

STRUCTURAL

No items

M.E.P

No items

End
